



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx CML 16.0099X**

Page 1 of 4

Certificate history:

Status: **Current**

Issue No: 6

[Issue 5 \(2019-08-16\)](#)

[Issue 4 \(2019-02-19\)](#)

[Issue 3 \(2018-01-04\)](#)

[Issue 2 \(2017-05-26\)](#)

[Issue 1 \(2017-01-12\)](#)

[Issue 0 \(2016-12-09\)](#)

Date of Issue: 2026-07-07

Applicant: **ABTECH Limited**
199/201 Newhall Road
Lower Don Valley
Sheffield S9 2QJ
United Kingdom

Equipment: **ABJB High Voltage Junction Box**

Optional accessory:

Type of Protection: **Ex sb, Ex op pr, Ex op is, Ex tb**

Marking: **High Voltage Junction Boxes**

Ex sb IIC T4 Gb or

Ex sb IIB T4 Gb

Ex tb IIIC T70°C/ T80°C Db

Ta= Up to -50°C to +55°C

Optical Enclosure

Ex * op is IIC T4 Gb or

Ex * op is IIB T4 Gb

Ex op is IIIC T70°C/ T80°C Db or

Ex * op pr IIC T4 Gb or

Ex * op pr IIB T4 Gb

Ex op pr IIIC T70°C/T80°C Db

Ta= Up to -40°C / -50°C to +55°C

** where enclosure also has an electrical connections, marking will also include Ex eb marking*

Approved for issue on behalf of the IECEx
Certification Body:

L A Brisk

Position:

Assistant Certification Manager

Signature:
(for printed version)

Date:
(for printed version)

07 Jul 2026

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Eurofins E&E CML Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port, CH65 4LZ
United Kingdom





IECEx Certificate of Conformity

Certificate No.: **IECEx CML 16.0099X**

Page 2 of 4

Date of issue: 2026-07-07

Issue No: 6

Manufacturer: **ABTECH Limited**
199/201 Newhall Road
Lower Don Valley
Sheffield S9 2QJ
United Kingdom

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-28:2015](#) Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation
Edition:2

[IEC 60079-31:2013](#) Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

[IEC 60079-33:2012](#) Explosive atmospheres – Part 33: Equipment protection by special protection "s"
Edition:1.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/CML/ExTR16.0127/00](#)
[GB/CML/ExTR18.0001/00](#)

[GB/CML/ExTR17.0004/00](#)
[GB/CML/ExTR19.0033/00](#)

[GB/CML/ExTR17.0093/00](#)
[GB/CML/ExTR26.0010/00](#)

Quality Assessment Report:

[GB/CML/QAR16.0021/13](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx CML 16.0099X**

Page 3 of 4

Date of issue: 2026-07-07

Issue No: 6

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The ABB are a range of High Voltage Junction Boxes

See Annex for full description and Conditions of Manufacture

SPECIFIC CONDITIONS OF USE: YES as shown below:

See Annex for Specific Conditions of Use



IECEX Certificate of Conformity

Certificate No.: **IECEX CML 16.0099X**

Page 4 of 4

Date of issue: 2026-07-07

Issue No: 6

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Issue 1

This issue introduced the following changes:

1. To correct a typographic error to the drawing list in the report

Issue 2

This issue introduced the following changes:

1. To allow an alternative ABB-8* bus bar layout arrangement.
2. To include an option to allowed the enclosure to be painted with a coating thickness up to 2mm for 'IIB' applications.

Issue 3

This issue introduced the following changes:

1. To allow the terminal and optical arrangements to be fitted in an alternative Nautilus enclosure. The description has been modified accordingly.

Issue 4

This issue introduced the following changes:

1. To clarify the minimum distances for the insulator arrangements.

Issue 5

This issue introduced the following changes:

1. To update QAR reference

Issue 6

This issue introduced the following changes:

1. To introduce new Ex parts to the scope of this equipment,
2. To add a 24kV version to the scope of this equipment,
3. To update to the latest standards.

Annex:

[Certificate Annex IECEx CML 16.0099X Issue 6.pdf](#)

Annexe to: IECEx CML 16.0099X Issue 6
Apparatus: ABBJ High Voltage Junction Boxes
Applicant: Abtech Limited



Description

The ABBJ 15kV & 24kV Range of High Voltage Junction Boxes are available in the following sizes:

Table 1 – Ratings for High Voltage Enclosure					
Junction box reference	Maximum Voltage (kV)	Ambient Temperature Range	Maximum power dissipation (W)	T Class	Dust Surface Temperature Marking
ABJB-7*	15kV	-20°C to +40°C	259W	T4	T70°C
		-50°C to +55°C	215W	T4	T80°C
ABJB-8*	15kV	-20°C to +40°C	346W	T4	T70°C
		-50°C to +55°C	288W	T4	T80°C
ABJB-125	15kV	-20°C to +40°C	346W	T4	T70°C
		-50°C to +55°C	288W	T4	T80°C
ABJB-24	24kV	-20°C to +40°C	438W	T4	T70°C
		-50°C to +55°C	365W	T4	T80°C
Note: Where* is either 2 (2 Way), 3 (3 Way) or 4 (4 Way), 5 (5Way) or 6 (6Way)					
Table 2 – Optical Power					
‘op pr’ applications			‘op is’ applications		
T4/T70°C at a maximum ambient of ≤40°C T4/T80°C at a maximum ambient of ≤55°C			T4/T70°C at a maximum ambient of ≤40°C T4/T80°C at a maximum ambient of ≤55°C		
When ‘op pr’ is used with or without terminals, the splice case is limited to 100mW and a -40°C to 55°C ambient temperature.			When ‘op is’ is used with or without terminals. Fibre optic source is limited to a maximum irradiance of 5mW/mm ² (surface area not exceeding 400mm ²) Signal power is limited to 35 mW@T4.		

The empty enclosures used for the ABBJ Junction Boxes are the Type SX Range of Enclosures, covered under IECEx CML 15.0039U and marked Ex eb IIC Gb / Ex tb IIIC Db. Alternatively, the terminal and optical arrangements may be fitted inside a Nautilus enclosure certified under IECEx CML 16.0100X.

Inside the enclosure, the ABBJ Range of Junction Boxes has an arrangement of up to 6 copper busbar assemblies to provide connection facilities.

The busbars are supported on insulators and may accommodate up to three cables per phase, a single cable per phase or a combination, depending on the arrangement. The connecting cables are terminated via cable lugs that are fitted between busbars and have insulated partitions to provide creepage and clearance distances between live parts.



Certificate Annex IECEx
Version: 12.0 Approval: Approved



Eurofins E&E CML Limited
Newport Business Park, New Port Road
Ellesmere Port, CH65 4LZ, UK



The ABB Junction Boxes may be fitted with a suitably certified and dimensioned heater and may have an optional isolated earth connection.

Optionally, an additional side terminal compartment may be provided for connection of fibre optic cables and a separate break-out box can be included to aid cable connections at the bottom of the main high voltage enclosure. The side terminal enclosure may be fitted with 'op pr' fibre optical splice cases and other 'op is' cable jointing facilities.

Cable entries used for the ABB Junction Box Enclosures shall be Ex eb IIC Gb and/or Ex tb IIIC Db, depending on the explosive atmosphere and shall be suitable for the lower ambient and 30°C above the upper ambient.

Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. The products covered by this certificate incorporate separately certified devices, it is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with these devices. The manufacturer shall inform CML of any modifications of the devices that may impinge upon the explosion safety of their design.

In addition, this certificate relies on the following previously certified products. When the Junction Box is fitted with anti-condensation heater that includes a thermostat; the key attributes listed in the table below shall still be maintained by their original certificate.

Description	Certificate No.	Key Attributes
Anti-Condensation heater fitted with a thermostat	As appropriate	Suitably certified by a notified/certification body as a piece of equipment Ex e, with a T6 temperature class and suitable for the exposed ambient temperature. The integral thermostat of the incorporated heater shall have a limiting temperature set to no higher than 10°C below the maximum upper ambient temperature marked on the enclosure (e.g. 30°C for Tamb +40°C, 45°C for Tamb +55°C). Appropriate creepage and clearances are still maintained

- ii. If the terminals are fitted with cables/wiring by the manufacturer; then a routine dielectric strength test shall be carried out on each unit in accordance with IEC 60079-7:2017, clause 7.1. The test voltage shall be determined on the basis of the marked maximum rated voltage, with the appropriate safety factor and test duration applied in accordance with IEC 60079-7:2017, clause 6.1. No flashover or breakdown shall occur.
- iii. When fitted with high voltage (15 kV maximum working voltage) terminals, the maximum dissipated power of the Junction Boxes shall be calculated in accordance with IEC 60079-7:2017, Annex E.2, and shall not exceed the maximum power rating defined in the Description on this certificate.



Certificate Annex IECEx
Version: 12.0 Approval: Approved



Eurofins E&E CML Limited
Newport Business Park, New Port Road
Ellesmere Port, CH65 4LZ, UK

- iv. When the equipment is marked for 'op pr' the extreme ambient temperature limit marking that can be applied is -40°C to +55°C
- v. Junction Boxes that are marked with the ambient range -50°C to +55°C shall only be constructed using an SX component enclosure with a minimum depth of 300 mm, without windows and fitted with silicone gaskets, as approved by IECEx CML 15.0039U.
- vi. The maximum ambient temperature of the equipment is dependent on the model and maximum power dissipation/current rating. The maximum ambient, power and voltage ratings shall be marked in accordance with the Description on this certificate and with the approved drawings listed on this certificate.
- vii. When optional adjacent non-metallic optical enclosure is fitted, non-carbon loaded enclosures shall be fitted with the static warning label required under its component approval.
- viii. When fitted with the Gas Detector, model XGard Bright, the following conditions must be met :
 - a. Unused cable entries must be sealed using an IECEx Ex db and Ex tb certified stopping plug with minimum IP65/IP66 ingress protection.
 - b. Only the cables/wires which are specified in the user manual can be used.
 - c. External earthing should be considered and installed according to user manual before use.

Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- i. For junction boxes used at voltage over 11kV and installed in a location where an explosive atmosphere is considered present under normal circumstances (Zones 1 or 21), the installer/user shall consider and take account of any additional risks posed by the location or the environment which may exacerbate electrical breakdown or corona discharge, such as humidity, condensation, or contaminants such as dusts, oils or greases. Additionally, the installer shall determine that the cables to be installed do not increase the ignition risk, (materials, size and secureness of connections). Cable sleeves and connection covers should be considered as a part of the cable termination.
- ii. During installation, the main supply screen (copper shield tape or braid) shall be twisted and crimped to a terminal lug at the end prior to being covered with heat shrink sleeving, and connected to the internal enclosure earth stud or the earth bar (where provided). When provided and used, dedicated insulated earth lead with suitable crimped terminal lugs at each end shall be provided between the earth bar and the enclosure earth stud. If an isolated earth bar is provided, e.g. for the connection of remote screen current monitoring, the main supply screen may be connected to this instead of to the enclosure earth stud.
- iii. When one or more isolated earth bars are provided and used for cable screens and/or cable armour, the user must ensure that a dedicated insulated earth lead is provided between the isolated earth bars then exiting the enclosure via a suitably certified IP66 cable gland. The cross section of the earth leads must be at least half that of the main supply conductors. All earth lead connection must include a crimped terminal lug and cables must be secured to the support rails to prevent reduction of the creepage and clearance distances.



Certificate Annex IECEx
Version: 12.0 Approval: Approved



Eurofins E&E CML Limited
Newport Business Park, New Port Road
Ellesmere Port, CH65 4LZ, UK

- iv. The following minimum creepage and clearance distances shall be maintained:

Model (Voltage)	Location	Creepage	Clearance
ABJB7, ABBB8, ABJB125 (15kV)	Phase to phase	194 mm	150 mm
	Phase to earth	115 mm	90 mm
ABJB21 (24kV)	Phase to phase	N/A	N/A
	Phase to earth	295mm	252mm

- v. Under certain extreme circumstances, the non-metallic parts of the optical enclosure (when fitted) of this equipment may generate an ignition-capable level of electrostatic charge. Therefore, the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.
- vi. When marked 'Ex op is', the fibre optic source supplying this equipment shall be suitably certified as compliant with at least IEC 60079-28:2006 or later and provide an inherently safe optical source (op is), EPL Gb, subsequently the parameters in Table 2 in the description apply. Additionally, the optical supply shall provide over-power fault protection suitable for an ELP level 'Gb'.
- vii. When marked 'Ex eb op pr', the fibre ST connectors contained within the optical enclosure must not be separated whilst energised if an explosive atmosphere may be present.
- viii. The ABBB Junction Boxes shall be installed in accordance with manufacturer's instructions document IOM0011.
- ix. When fitted with the Mini-thermostat type IRM**/**, the final user must ensure that the circuit of the mini-thermostat is protected by a circuit breaker with tripping characteristic C to the rated current of 16A.
- x. Where the equipment is fitted with the explosion-protected electrical sensor type ExBin-..., the intrinsically safe function shall be rendered inoperative. Under this configuration, the intrinsically safe circuit(s) shall not be used, connected, or made available for operation, as the requirements for intrinsic safety protection are not ensured when this sensor type is installed.

Components used which are covered by Ex Certificates issued to older editions of Standards

None.