



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx IBE 17.0016** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2017-07-31

Applicant: **Adolf Schuch GmbH, Lichttechnische Spezialfabrik**
Mainzer Straße 172
67547 Worms
Germany

Equipment: **LED Emergency Light Fitting type e864.12L../.**

Optional accessory:

Type of Protection: **Increased safety "e" in combination with encapsulation "m", powder filling "q" and flameproof enclosure "d" or protection by enclosure "t"**

Marking: Ex db eb [ib] mb op is q IIC T4 Gb
Ex op is tb IIIC T80 °C Db

Approved for issue on behalf of the IECEx
Certification Body:

Prof. Dr. Tammo Redeker

Position:

Head of Certification Body

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

IBExU Institut für Sicherheitstechnik GmbH
Certification Body
Fuchsmühlenweg 7
09599 Freiberg
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX IBE 17.0016**

Page 2 of 3

Date of issue: 2017-07-31

Issue No: 0

Manufacturer: **Adolf Schuch GmbH, Lichttechnische Spezialfabrik**
Mainzer Straße 172
67547 Worms
Germany

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2011 Explosive atmospheres - Part 0: General requirements
Edition:6.0

IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-18:2014 Explosive atmospheres – Part 18: Equipment protection by encapsulation "m"
Edition:4.0

IEC 60079-28:2015 Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation
Edition:2

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

IEC 60079-5:2015 Explosive atmospheres –Part 5: Equipment protection by powder filling "q"
Edition:4.0

IEC 60079-7:2015 Explosive atmospheres – Part 7: Equipment protection by increased safety "e"
Edition:5.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/IBE/ExTR16.0056/00](#)

Quality Assessment Report:

[DE/PTB/QAR09.0004/04](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx IBE 17.0016**

Page 3 of 3

Date of issue: 2017-07-31

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The LED Emergency Light Fitting of type e864.12L.../.. is a LED luminaire with emergency light function that is suitable for use in areas with potentially explosive gas and dust atmospheres of zone 1, 2, 21 and 22. The luminaire consists of a polyester enclosure, an assembly plate / reflector with LED modules in encapsulation, LED emergency electronic and terminals, and a light-transmitting cover made of polycarbonate as well as flameproof switches. Additionally, the luminaire is equipped with a replaceable battery pack for emergency light function. The battery pack is mounted in a separate enclosure that is attached to the side of the luminaire. The state of charge is indicated by a coloured LED. This LED is inside the enclosure and has been considered as simple apparatus. Optionally, the output current for supplying the LEDs may be set by means of DALI-Interface.

Technical data:

Nominal input voltage:	220 V...240 V AC
Input power:	up to 50 W (typically)
Battery:	NiCd 6 V / 4 Ah or NiCd 6 V / 1.6 Ah
Through-wiring:	up to 12 x $\geq 2.5 \text{ mm}^2$ (maximum 4 x 16 A)
ambient temperature range:	-30 °C...maximum +60 °C

These values are maximum values. The actual values are determined by the built-in components. The manufacturer specifies the rated values in the context of these limiting values and ensures compliance with the maximum surface temperature of the equipment and the permissible operating temperature of the components. Through-wiring, selection of the cable and cable gland may be restricted in some types of the luminaire.

SPECIFIC CONDITIONS OF USE: NO